

REQUEST FOR QUOTATION

Section 52.1b - Shopping

RFQ NO. 2025-03-18-269
DATE: 18-Mar-2025

COMPANY NAME :
COMPANY ADDRESS :
CONTACT PERSON :
CONTACT NO. :
COMPANY TIN :

10MS-2023-02-17-004
POSTED
SEPS REF No.: 11897863
DATE: 03/19/2025
SIGNATURE: _____

Sir/Madam:

Please quote your government price/s including delivery charges, VAT or other applicable taxes, and other incidental expenses for the goods listed in **Annex A**. Failure to indicate **TECHNICAL SPECIFICATIONS** could be basis for non-compliance. Also, furnish us with the descriptive brochures, catalogues, literatures and/or samples, if applicable.

If you are the exclusive manufacturer, distributor or agent in the Philippines for the goods listed in Annex A please attach in your quotation a duly notarized certification to this effect.

Please submit this form together with Annex A to **DSWD FO IX BAC OFFICE** on or before **24 MAR 2025 @ 05:00 PM**

Very truly yours,

ROLANDO V. CUEVA
Regional Procurement Officer

Terms and Conditions:

- PURPOSE** : DATA CENTER COMPLIANCE TO ISO 27001
- PR NUMBER** : 2025-02-17-84
- 1. Award shall be made on per : Item Basis Lot Basis
- 2. Quotation validity : 30 CALENDAR DAYS FROM BID OPENING
- 3. Goods shall be delivered on : **20 CALENDAR DAYS UPON RECEIPT OF PO**
- 4. Delivery Area : **DSWD FO IX**
- 5. Terms of payment : W/ IN 60 CALENDAR DAYS AFTER DELIVERY
- 6. Liquidated Damages/Penalty : 1/10 of 1% of undelivered portion x No. of days of delay
- 7. In case of discrepancy between unit cost and total cost, unit cost shall prevail.
- 8. Warranty : N/A
- 9. Performance Security : N/A

(signature over printed name)
Supplier

PHILGEPS NO.: _____
PHILGEPS EXPIRY: _____



COMPANY NAME
COMPANY ADDRESS
CONTACT PERSON
CONTACT NO.

Section 52.1b - Shopping

ANNEX A: RFQ
RFQ NO. : 2025-03-18-289
DATE : 2025-03-18

ITEM NO.	QTY	UNIT	PURCHASERS SPECIFICATIONS	TOTAL AMT	BIDDER'S SPECIFICATIONS	UNIT COST	TOTAL COST
1	1	LOT					
1	1	UNIT	FIRE EXTINGUISHER FOR SERVER AND ICT EQUIPMENT INSIDE THE DATA CENTER EXTINGUISHING AGENT FK 5112 PROPELLANT : NITROGEN BODY DIAMETER : 185 MM TOTAL HEIGHT : 540 MM APPROX TOTAL WEIGHT : 13.4 KG OPERATING TEMPERATURE : -30 DEGRESS CELCIUS TO 60 DEGRESS CELCIUS TEST PRESURE 30 BAR				
2	1	UNIT	SMOKE, HEAT AND FIRE SMART DETECTOR SMART WIFI SMOKE AND CARBON MONOXIDE DETECTOR W/ MONITORING APPLICATION AND CAPABLE OF SENDING NOTIFICATION THRU EMAIL AND SMART PHONE WHEN ALARM IS TRIGGER. DUAL SENSORS THAT DETECT BOTH SMOKE AND CARBON MONOXIDE WITH CLEAR DIGITAL DISPLAY WITH LED INDICATOR COLORS RED FOR ALARM GREEN FOR NORMAL AND YELLOW FOR FAULT DETECTION RANGE AT LEAST 15M SQ.	113,000.00			
3	2	UNITS	VERTICAL METERED PDU FOR SERVER/DATA RACK HEAVY DUTY WITH LED/LCD DISPLAY MONITORING WITH BUILD IN SAFETY BREAKER (20 AMPS) HEIGHT: 56-80 INCHES WIDTH AT LEAST 2 INCHES AT LEAST WITH 18 IEC 60320 C13 OUTLET INPUT VOLTAGE: 200 V, 208 V/230, 240 ; MOUNTING LOCATION & POSITION: VERTICAL RACK SIDE MOUNT WITH MOUNTING KIT/LOAD CAPACITY: 3300 VA				
4	1	UNIT	18" WALL MOUNTED DATA CABINET WITH MOUNTABLE POWER STRIP WITH 4 FANS 120 MM STEEL MESH FRONT DOOR REMOVABLE WITH SECURE LOCK SIDE PANEL REMOVABLE WITH SECUR LOCK MADE OF STEEL COLOR BLACK INTERNAL WIDTH AT LEAST 23.5 IN /INTERNAL DEPTH AT LEAST 21.7 IN, HEIGHT : 18 U XXXXXXXXXXXXXXXX PLS SEE ATTACHED SAMPLE PICTURE (WITH 1 YEAR WARRANTY)				

PURPOSE : DATA CENTER COMPLIANCE TO ISO 27001
PRJ. NO. : 2025-02-17-84

[Signature]
SCHLEINE A. INSONG
CANVASSER

DOCUMENTS REQUIRED DURING RFQ OPENING:
1. Mayor's Permit
2. Philgeps Registration Number

(SIGNATURE OVER PRINTED NAME)
SUPPLIER

